

LOCATION 2007 Audrey Dr CITY Gastonia
BETWEEN Pamela st. STREET & Helen Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>189'</u>			<u>7-8-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>54'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>135'</u>			


ENTERS: Same BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 220' From @ of Pamela st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DF
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION NORTHside of Audrey

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY