

LOCATION 2011 Audrey Dr. CITY CAS.  
BETWEEN HELEN st. STREET & PAMELA st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>122'</u>		<u>7-</u>	<u>8-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>56'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>66'</u>			

ENTERS: same BRANCHED INTO:  
TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 293' From @ of  
HELEN


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION North Side of Audrey Dr.

"A" P/S READING P. TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY