

LOCATION 2606 Ashborne Ln CITY Gastonia
BETWEEN Lisemore Ln STREET & Waterford Ln STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>133'</u>	<u>11/4/91</u>		
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>13'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>120'</u>			

ENTERS: 2606 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1991
DEPTH: 3 FT. 0 IN. LOCATION _____

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # 256054

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R. SE</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY