

LOCATION 3015 Audrey DR CITY Gastonia

BETWEEN Ridgeway STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>160'</u>	<u>2-14-00</u>	<u>Retired (Ctu) Service.</u>	
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>50'</u>		<u>Purged with Air &amp; Foamed</u>	
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>110'</u>		<u>2-14-00</u>	

ENTERS: Same BRANCHED INTO:

TAP SIZE: 1/4" PRESSURE 600 PSI INCHES W C LOCATION 26' west of Audrey +  
318' South of Ridgeway.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS. BY RR

MAIN-SIZE 2" C I        BARE STEEL        COATED STEEL ✓ PLASTIC        YEAR INSTALLED 1979

DEPTH: 3 FT 6 IN. LOCATION 26' west of Audrey DR.

"A" P/S READING 1.3 TOTAL ANODES 1# — 17# — I.R. # —

REMARKS: Retired & Renewed service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	