

LOCATION 3608 Augusta Ct. CITY GASTONIA
BETWEEN Cloister Dr. STREET & End of Caldesack STREET


| | SIZE | TYPE | LENGTH | INSTALLED | RETIRED | RENEWED |
|---------------------|------------|----------------|------------|---------------|---------|---------|
| MAIN TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>66'</u> | <u>1-3-96</u> | | |
| MAIN TO PROP. LINE | <u>3/4</u> | <u>Plastic</u> | <u>10'</u> | | | |
| PROP. LINE TO BLDG. | <u>3/4</u> | <u>Plastic</u> | <u>56'</u> | | | |

ENTERS: 3608 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 393' N of Cloister Dr.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED-STEEL _____ PLASTIC J YEAR INSTALLED 1989
DEPTH: 3 FT. 0 IN. LOCATION 18' W of Cloister Augusta Ct.

"A" P/S READING Plastic N/A TOTAL ANODES 1# _____ 17# _____ L.R. # 641622

REMARKS:

|  | Test Station | | | ENG. DEPT. USE ONLY |
|--|--|----------|----------------------|---------------------|
| | Reading & Location | Lead | Volts | |
| | P/S Pipeline Lead - Red New Service | <u>S</u> | <u>Riser Plastic</u> | |
| | P/S Pipeline Lead - White Existing Main | <u>E</u> | | |