

LOCATION: 1521 Auten Rd. CITY Gastonia
 BETWEEN N. New Hope Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
serv. TO BLDG	3/4	P	61'	3-16-01	Retired	70' of 3/4"
serv. TO PROP LINE	3/4	P	40'		CFA Service. Purged with Air & foamed.	
PROP LINE TO BLDG	3/4	P	27'			

ENTERS 1206 N. New Hope Rd BRANCHED INTO
 TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 96' North of
Auten Rd. & 152' East of N. New Hope Rd.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. BALLARD


~~serv.~~ SIZE 3/4 C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 2001

DEPTH 2 FT 6 IN LOCATION 96' North of Auten Rd & 152' East
of N. New Hope Rd.

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — LR # 00195546

REMARKS

Retired & Renewed Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P. Riser
P/S Pipeline Lead - White Existing Main	E	