

LOCATION 1543 Auten Rd. CITY Gastonia
BETWEEN Pine Ridge Rd STREET & N. New Hope Rd STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>130'</u>	<u>2-2-01</u>	<u>Retired 130' of 1"</u>	
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>40'</u>		<u>BARE. Purged & Foamed.</u>	
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>90'</u>		<u>1958</u>	

ENTERS Same BRANCHED INTO
TAP SIZE 1/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 13' South of
Auten Rd & 234' west of Pine Ridge.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. BALLARD
MAIN-SIZE 4" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED _____
DEPTH 3 FT 6 IN LOCATION 13' South of Auten Rd.

"A" P/S READING .85 TOTAL ANODES 1# _____ 17# 1 LR # _____

REMARKS.
Retired & Renewed Service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>p. Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

60' Bore
60' Plow
10' Trench