

LOCATION 1622 Anter Rd CITY Stonington

BETWEEN Brookneal STREET & Rhonda STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>74</u>	<u>8-23-94</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>7</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>67</u>			

ENTERS: 1622 BRANCHED INTO:

TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Near house


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By Bennett

MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1959

DEPTH: 2 Ft. 6 In. LOCATION 13' E of C.A.H.

"A" P/S READING 1.20 TOTAL ANODES 1# _____ 17# _____ L.R. # 00353268

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY