

LOCATION 1812 Autens Rd CITY GASTONIA  
BETWEEN Fairlane Dr. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>CW</u>	<u>3'</u>	<u>Relocated 10-6-98</u>		
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS: 1812 BRANCHED INTO: 0

TAP SIZE: 3/4" S PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 14 HRS. BY EP

MAIN-SIZE 3/4 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED \_\_\_\_\_

DEPTH: 1 FT. 6 IN. LOCATION

"A" P/S READING 1.1 TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.1</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY