

LOCATION	2320 Autumnwood Trail		CITY	Canton, N.J.		
BETWEEN	Mablewood Ct		STREET &	Cul-de-Sac		STREET
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	217'	6-14-99		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	172'			
ENTERS:	2320		BRANCHED INTO:			
TAP SIZE:	1/2	PRESSURE	42 PSI	INCHES W.C.	LOCATION 544' E. of center of Mablewood Ct	
PRESSURE TEST:	100	PSI	FOR 1/4	HRS	BY S.H.	
MAIN-SIZE	2"	C.I.	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED
DEPTH:	3 FT.	0 IN	LOCATION 14' N. of center of Autumnwood Trail			
"A" P/S READING	P		TOTAL ANODES 1#	2	17#	2
			I.R. #	480499		

REMARKS:

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	