

LOCATION 203 S. Avon St. CITY Castoria
BETWEEN Franklin Blvd. STREET & 2nd Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>21'</u>	<u>10-14-93</u>	<u>Tied over</u>	<u>12' Existing 3/4</u>
MAIN TO PROP. LINE					<u>Plastic</u>	
PROP. LINE TO BLDG.					<u>Retired 20'</u>	<u>Existing 3/4 Plastic</u>

ENTERS: 203 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 180' S of C of Franklin Blvd.

PRESSURE TEST: @ 100 psi For 14 Hrs. By RL


MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 16' W of C of Avon St.

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY