

LOCATION 211 & 203 1/2 S. Avon St. CITY GASTON, IA  
BETWEEN Franklin Blvd. STREET & 2nd Ave. STREET

|                     | SIZE       | TYPE     | LENGTH    | INSTALLED       | RETIRED                             | RENEWED |
|---------------------|------------|----------|-----------|-----------------|-------------------------------------|---------|
| MAIN TO BLDG.       | <u>3/4</u> | <u>P</u> | <u>3'</u> | <u>10-13-93</u> | <u>Tied over 60' on 211 3/4 CtW</u> |         |
| MAIN TO PROP. LINE  |            |          |           |                 | <u>Tied over 58' 3/4 CtW on</u>     |         |
| PROP. LINE TO BLDG. |            |          |           |                 | <u>203 1/2 Yellow Cab Garage</u>    |         |


ENTERS: 211 BRANCHED INTO: 203 1/2  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 280' N of C of 2nd Ave.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL  
MAIN-SIZE 2" C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1993  
DEPTH: 3 Ft. 0 In. LOCATION 16' E of C of Avon St.

"A" P/S READING P TOTAL ANODES 1\*     17\*     L.R. #    

REMARKS: Tied Tracer wire OFF AT Tee.

Bare Main Replacement  
Purged With Air And  
Capped With Main



| Test Station                               |      |  | ENG. DEPT. USE ONLY |
|--|------|--|---------------------|
| Reading & Location                         | Lead | Volts  |                     |
| P/S Pipeline Lead - Red<br>New Service     | S    | <u>Riser 211 1.1</u><br><u>Riser 203 1/2 1.1</u> |                     |
| P/S Pipeline Lead - White<br>Existing Main | E    |  |                     |