

LOCATION 321 5-Avenue St.

CITY GASTONIA

BETWEEN 3rd Ave.

STREET & 2nd Ave.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	10-5-93	Tied over 60'	
MAIN TO PROP. LINE					Existing 3/4 C/W to	
PROP. LINE TO BLDG.					new PLASTIC MAIN	

ENTERS: 321

BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 295' N of C of 3rd Ave.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 14' W of C of Aven St.

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS: Tied Tracer Wire OFF At Tee

Bare Main Replacement
Program

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser 1.2
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY