

LOCATION 323 5. Avon CITY Gastonia
BETWEEN 2nd STREET & 3rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'		Tied over	60' of
MAIN TO PROP. LINE					Ext 3/4" gal to Ext	
PROP. LINE TO BLDG.				10-6-93	2" Plastic	Main

ENTERS: 323 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 13' W of Co F Avon
222' W of Co F 3rd

PRESSURE TEST: @ 100 psi For 14 Hrs. By EP


MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1892

DEPTH: 3 Ft. 6 In. LOCATION

"A" P/S READING P TOTAL ANODES 1* 017* 0 L.R. #

REMARKS:

Tie wire tied off at Main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S R. 500	1.1
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY