

LOCATION 406 S. Avon St. CITY GASTONIA
BETWEEN 3rd Ave. STREET & Maple St. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P.</u>	<u>47'</u>	<u>8-21-93</u>	<u>Tied over</u>	
MAIN TO PROP. LINE					<u>20' Existing</u>	
PROP. LINE TO BLDG.					<u>3/4 P.</u>	

ENTERS: 406 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 228' S of Cor 3rd Ave.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL


MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 13' W of Cor S. Avon St.

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS:

Bare Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY