

LOCATION 622 & 624 S. Duon CITY Cambridge
BETWEEN 6th STREET & 5th STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>32'</u>	<u>8-28-93</u>	<u>Tied over 620 P&H</u>	
MAIN TO PROP. LINE					<u>3/4 C/W Service to</u>	
PROP. LINE TO BLDG.					<u>EXT 2" Plastic main</u>	

ENTERS: 622 BRANCHED INTO: 624
TAP SIZE: 1/2 PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION 11' E of 60 P Avon
125' S of 60 P 6th

PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By EP
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1993
DEPTH: 3 Ft. 6 In. LOCATION _____

"A" P/S READING P TOTAL ANODES 1* 17* _____ L.R. # _____

REMARKS:
Tinner wire tied off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>R 300</u>	<u>1.2</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY