

LOCATION 3505 Barrington Dr. CITY GASTON, N.C.

BETWEEN Kendrick Rd. STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	98'	P	118'	1-8-00		
MAIN TO PROP LINE	578'	P	18'			
PROP LINE TO BLDG	578'	P	100'			

ENTERS 3505 BRANCHED INTO _____

TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 487' N. of center of Kendrick Rd.


PRESSURE TEST @ 100 PSI FOR 1 1/4 HRS BY S.C.

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH 3 FT 0 IN LOCATION 12' W. of center of Barrington Dr.

"A" P/S READING 0.914 TOTAL ANODES 1# 0 17# 0 LR # 160389

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	