

LOCATION 3500 BARRINGTON DR CITY GASTONIA  
BETWEEN KENDRICK STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>52'</u>	<u>9-3-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>47'</u>			

ENTERS 3504 BRANCHED INTO 3500  
TAP SIZE 3/8 PRESSURE 600 PSI INCHES W C LOCATION

PRESSURE TEST @ 600 PSI FOR 1 1/4 HRS BY EP

MAIN SIZE 3/4 C I BARE STEEL COATED STEEL X PLASTIC YEAR INSTALLED

DEPTH 1 FT 0 IN LOCATION

"A" P/S READING 1.7 TOTAL ANODES I# 010 L.R. #

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plastic</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

