

LOCATION 2002 BARRONWOOD CT.

CITY GASTONIA

BETWEEN HEATHWOOD DR.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PL.	53'	11-12-98		
MAIN TO PROP. LINE	3/4"	PL.	12'	11-12-98		
PROP. LINE TO BLDG.	3/4"	PL.	41'	11-12-98		

ENTERS: 2005 BARRONWOOD CT.

BRANCHED INTO: 2002 BARRONWOOD CT.

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 9' SOUTH OF C. OF BARRONWOOD CT.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY R. Pullady

SERVICE MAIN SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 2 FT. IN. LOCATION 427' EAST OF C. OF HEATHWOOD DR.

"A" P/S READING PL. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY