

LOCATION 2018 Branwood CT. CITY CASBAND

BETWEEN Heathwood Dr STREET & Cut-de-Sac STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>108'</u>	<u>7-21-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>35'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>73'</u>			

ENTERS: 2018 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI                      INCHES W.C. LOCATION 94' E. of center of

Heathwood Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. HUFFSTETTER

MAIN-SIZE 2" C.I.            BARE STEEL            COATED STEEL            PLASTIC ✓ YEAR INSTALLED           

DEPTH: 3 FT. 0 IN. LOCATION 20' S. of center of Branwood CT.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 420963

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<b>S</b>	
P/S Pipeline Lead - White Existing Main	<b>E</b>	

ENG. DEPT. USE ONLY