

LOCATION 2117 BARRONWOOD CT.

CITY GASTONIA

BETWEEN HEATHWOOD DR.

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PL.	56'	11-12-98		
MAIN TO PROP. LINE	3/4"	PL.	4'	11-12-98		
PROP. LINE TO BLDG.	3/4"	PL.	52'	11-12-98		

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 169' EAST OF CENT. OF HEATHWOOD DR.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY A. Ruller

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1996

DEPTH: 3 FT. IN. LOCATION 20' SOUTH OF CEN. OF BARRONWOOD CT.

"A" P/S READING PL. TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY