

LOCATION- 907 Baxter CITY GASTONIA
BETWEEN N. Rhine STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>76'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>2'</u>	<u>5299</u>		
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>74'</u>			

ENTERS 907 BRANCHED INTO 0

TAP SIZE: 3/8 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1967

DEPTH: 2 FT 6 IN LOCATION _____

"A" P/S READING _____ 16 TOTAL ANODES in 0 17# 1 I.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Plaster</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	