

LOCATION 3606 Baywoods Ct. CITY Gastonia
BETWEEN Gaston Day School Rd. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>		<u>8-1-00</u>	<u>Retired 48'</u>	<u>Renewed 72'</u>
MAIN TO PROP. LINE					<u>of existing 3/4"</u>	<u>New 3/4"</u>
PROP. LINE TO BLDG					<u>Plastic Service</u>	<u>Plastic Service</u>

ENTERS 3606 Baywoods BRANCHED INTO
TAP SIZE 3/4 PRESSURE 60 PSI INCHES W C LOCATION 128' E. Baywood Ct.
208' S. Gaston Day School Rd.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY C.R.

serv. ~~main~~ SIZE 3/4 C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT 6 IN LOCATION 128' E. Baywoods Ct.
208' S. Gaston Day School Rd.

"A" P/S READING N/A TOTAL ANODES 1# 17# L.R. #

REMARKS. Retired existing service under new addition to house.
Renewed 72' of 3/4" plastic.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P.Rise</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	