


LOCATION	2631 Ashbourne Dr.			CITY	GASTON, N.C.	
BETWEEN	Waterford Green			STREET &	Lismore Ln.	
	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	3/4"	P	142'	7-16-99		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG	3/4"	P	97'			
ENTERS.	2631			BRANCHED INTO.		
TAP SIZE	3/4"	PRESSURE	60	PSI	INCHES W.C.	LOCATION 128' SW of center of Lismore Ln.
PRESSURE TEST @	100	PSI	FOR	1/4	HRS	BY S.H.
MAIN SIZE	2"	C.I.	BARE STEEL	COATED STEEL	PLASTIC	YEAR INSTALLED
DEPTH.	3 FT	0 IN	LOCATION	28' SE. of center of Ashbourne Dr.		
"A" P/S READING	P			TOTAL ANODES 1#	0	17# 0
				L.R. #	576242	

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	