

LOCATION 313 Beacon Hills Dr CITY Gastonia

BETWEEN Beckington CT. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>109'</u>	<u>6-5-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>40'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>60'</u>			

ENTERS 313 BRANCHED INTO

TAP SIZE 3/4" PRESSURE 60 PSI INCHES W C LOCATION 75' NW. of center of Beckington CT.


PRESSURE TEST @ 100 PSI FOR 4 HRS BY S.H.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 17' S.W. of center of Beacon Hills Dr.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 LR # 138160

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	