

LOCATION 316 Beacon Hill Dr CITY Gastonia

BETWEEN B Ridgeport Ln STREET & _____ STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>68'</u>	<u>9-11-06</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>8'</u>			
PROP. LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>60'</u>			

ENTERS: 316 BRANCHED INTO: _____

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W/C LOCATION 17' South of Beacon Hill Dr to 10' west of Beckingham Ct.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY BB

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH: 3 FT 0 IN LOCATION 17' South of Beacon Hill Dr

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ I.R. # 00803771

REMARKS: New Plastic Service.



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	