

LOCATION 319 BEACON HILLS DR CITY CASTONIA

BETWEEN BECKINGHAM CT STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>103'</u>	<u>6-8-01</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>33'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>20'</u>			

ENTERS 319 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 60 PSI INCHES-WG LOCATION 194'S OF E of BECKINGHAM CT


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY R.R

MAIN-SIZE 2" CI BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 15' W of C of BEACON HILLS DR

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # A0451093

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>2.1v</u>