

LOCATION 402 Beatrice Costner CITY Gast.
BETWEEN Grace st. STREET & Moran st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>55'</u>			<u>9.2-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>15'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>40'</u>			


ENTERS: SAME BRANCHED INTO:
TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 40' From (C) of
Grace st.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY D.F.
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 2 FT. 8 IN. LOCATION s. of Beatrice Costner

"A" P/S READING P. TOTAL ANODES 1# - 17# - L.R. # -

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY