

LOCATION 2703 Beaty Rd. Bldg. FCITY CANTONIABETWEEN HedgeStone Dr.STREET & Marbregor Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>176'</u>	<u>3-3-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>plastic</u>	<u>0'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>plastic</u>	<u>176'</u>			


ENTERS: 2703BRANCHED INTO: 0TAP SIZE: 1/2PRESSURE 60

PSI

INCHES W.C.

LOCATION 232' S of Cog HedgeStone Dr.PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RLMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1992DEPTH: 3 FT. 0 IN. LOCATION 234' W of Cog Beaty Rd."A" P/S READING plastic N/ATOTAL ANODES 1# 0 17# 0L.R. # 135789

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>plastic</u>

ENG. DEPT. USE ONLY