

LOCATION 2840 Beatty Rd CITY San Antonio
BETWEEN Colwood St STREET & MacGregor STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>130</u>	<u>Replaced 6-20-94</u>		
MAIN TO PROP. LINE			<u>0</u>			
PROP. LINE TO BLDG.			<u>130</u>			

ENTERS: 2840 BRANCHED INTO:
TAP SIZE: 3/4 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side House


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By J. Smith

MAIN-SIZE 3/4 Ser C.I. _____ BARE STEEL _____ COATED STEEL / PLASTIC _____ YEAR INSTALLED _____

DEPTH: _____ Ft. _____ In. LOCATION 421' E of Rd

"A" P/S READING 1010 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY