

LOCATION 2854 Beatty Rd CITY Gastonia

BETWEEN McGREGORY Rd STREET & COLVARD St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>738'</u>	<u>5-18-98</u>		
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>693'</u>			

ENTERS: 2854

BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES W.C. LOCATION 16' N. of cor
Beatty


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY JP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1959

DEPTH: 3 FT. 6 IN. LOCATION _____

"A" P/S READING 1.30 TOTAL ANODES 1# 1 17# 1 L.R. # 00349040 (5-13-98)

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>RE</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY