

LOCATION 3017 Bealy Rd. CITY Gastonia

BETWEEN Duncan Ln. STREET & Maplecrest Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>77'</u>	<u>10-13-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>20'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>57'</u>			

ENTERS: 3017 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 240' N. of center of Duncan Ln.


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Duckett

MAIN-SIZE 3" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1959

DEPTH: 3 FT. 0 IN. LOCATION 10' W. of center of Bealy Rd.

"A" P/S READING 1.2 TOTAL ANODES 1# 0 17# 0 L.R. # 689550

REMARKS:

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	