

LOCATION 3212 Beauty Rd CITY GASTONIA

BETWEEN Kendrick Rd STREET & Valley Dale Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	100'	11-4-85		
MAIN TO PROP. LINE	1"	"	25'			
PROP. LINE TO BLDG.	1"	"	75'			

ENTERS: 3212 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION 11' S. of Cap of Beauty Rd


PRESSURE TEST: @ 100 psi For 1/4 hr Hrs. By AP

MAIN-SIZE 3" C.I. — BARE STEEL — COATED STEEL ☒ PLASTIC — YEAR INSTALLED 1959

DEPTH: 3 Ft. 0 In. LOCATION

"A" P/S READING 1.00 TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY