

LOCATION 3325 + 3321 Beatty Rd

CITY Gastonia

BETWEEN Valleydale

STREET &

Miller Dr

STREET

	SIZE	TYPE	3325 LENGTH	3321	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	60'	160'	11-9-93		
MAIN TO PROP. LINE	3/4	P	3'	43'			
PROP. LINE TO BLDG.	3/4	P	57'	117'			

ENTERS: 3321 Beatty Rd

BRANCHED INTO: 3325 Beatty Rd

TAP SIZE: 1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION 509' E of Miller Dr

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S Elmore

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC — YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In.

LOCATION 11' S of Beatty Rd


"A" P/S READING P

TOTAL ANODES 1# — 17#

L.R. # 403515

439755

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY