

LOCATION 3327 Beaty Rd CITY GASTONIA
BETWEEN Miller Dr. STREET & VALLYDALE STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	315'	9/24/96		
MAIN TO PROP. LINE	3/4		45'			
PROP. LINE TO BLDG.	3/4		270'			

ENTERS: 3327 BRANCHED INTO:
TAP SIZE: 1/2" PRESSURE 60 PSI _____ INCHES W.C. LOCATION North side of 3327


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DT

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC — YEAR INSTALLED 1993

DEPTH: 3 FT. 0 IN. LOCATION East side of Beaty Rd

"A" P/S READING 0 TOTAL ANODES 1# 0 17# 0 L.R. # 510431

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY