

LOCATION 1007 Ashton Ave. CITY Gastonia  
BETWEEN Summit STREET & Miller STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3 1/4"</u>	<u>P</u>	<u>61'</u>		<u>8-24</u>	<u>.93</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>7'</u>		<u>54' of 1" BARE</u>	
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>54'</u>			

ENTERS: 1007 Ashton Ave. BRANCHED INTO:

TAP SIZE: 1 1/2" PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION E. Side of 1107


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By JE

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1993

DEPTH: 3 Ft. \_\_\_\_\_ In. LOCATION N. Side of Ashton

"A" P/S READING P TOTAL ANODES 1\* - 17\* - L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY