

LOCATION 1009 & 1020 Ashton Ave

CITY GASTONIA

BETWEEN Summit Ave

STREET & Miller St

STREET

	SIZE	TYPE	100' LENGTH	1020	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	110'	32'		8-	93
MAIN TO PROP. LINE	3/4	P	5'	4'		1009 ASHTON AVE 120' of 3/4" BARE	
PROP. LINE TO BLDG.	3/4	P	105'	28'		1020 ASHTON AVE 60' of 3/4" C&W	

ENTERS: 1009 & 1020 Ashton Ave BRANCHED INTO: 1020 Ashton Ave

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 99' w of Miller St


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. E. Moore

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION: 13' N of Ashton Ave

"A" P/S READING P TOTAL ANODES 1# 17# L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY