

LOCATION 1220 Ashton Ave

CITY Gastonia

BETWEEN VANCE

STREET & MILLON

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	56'			9-2-93
MAIN TO PROP. LINE	3/4	P	7'		63' of 1" BARE	
PROP. LINE TO BLDG.	3/4	P	49			

ENTERS: 1220 Ashton Ave

BRANCHED INTO: -

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 71' W of millon st


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Elmer

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 13' N of Ashton Ave

"A" P/S READING P TOTAL ANODES 1* 17* L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY