

LOCATION 2590 ashbourne Dr. CITY Gastonia
 BETWEEN Aragalin Dr. STREET & Waterford Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>36'</u>	<u>3-2-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>6'</u>			
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>80'</u>			

ENTERS 2590 ashbourne Dr BRANCHED INTO Ø
 TAP SIZE 1/2" PRESSURE 60 PSI INCHES W C LOCATION 127' west


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.R. of center of Waterford Ln.

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1999

DEPTH: 3' FT 3" IN LOCATION 19' south of center of ashbourne Dr.

"A" P/S READING N/A TOTAL ANODES 1# Ø 17# Ø LR # 00176544

REMARKS. New 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>