

LOCATION 1017 Athenian Dr. CITY GASTOWIA  
BETWEEN PARAMOUNT Circle STREET & Home Trail STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>90'</u>	<u>10-20-93</u>	<u>100' Existing</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>		<u>3/4 C&amp;W &amp;</u>	
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>85'</u>		<u>15' 3/4 Plastic</u>	

ENTERS: 1017 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 148' S of C of Paramount Circle


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 4" C.I.     BARE STEEL     COATED STEEL     PLASTIC ✓ YEAR INSTALLED 1990

DEPTH: 3 Ft. 0 In. LOCATION 18' W of C of Athenian Dr.

"A" P/S READING P TOTAL ANODES I#     I7#     L.R. #    

REMARKS: Renewed Existing Tied over Service which was leaking under Driveway  
3/4 C&W. Driveway Concrete



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY