


LOCATION 408 Beech ST CITY GASTONIABETWEEN POPLAR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	PLASTIC	96'	11/25/96		
MAIN TO PROP. LINE	3/4"		22'			
PROP. LINE TO BLDG.	3/4"		74			

ENTERS: 408 BRANCHED INTO:TAP SIZE: 3/8" PRESSURE 60 PSI INCHES W.C. LOCATION NORTH side of 408PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DTMAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC YEAR INSTALLED 1963DEPTH: 2 FT. 6 IN. LOCATION 9' West of Center line Beech st"A" P/S READING 1.20 TOTAL ANODES 1# 0 17# 0 I.R. # 34420

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		