

LOCATION 1424 Beechwood st. CITY Gastonia
BETWEEN W. Rankin STREET & N. Boyd st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
<i>service</i> MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>32'</u>	<u>3-23-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>6'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>26'</u>	<u>"</u>		


ENTERS 1424 Beechwood st. BRANCHED INTO 1422 Beechwood st.
TAP SIZE 3/8" PRESSURE 40 PSI _____ INCHES W.C. LOCATION 298' north

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY S.R. center of W. Rankin st.

service MAIN SIZE 3/4" C I _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1963
DEPTH 2' FT 0" IN LOCATION 43' West of center of Beechwood st.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 LR # 00125197

REMARKS New 3/4" P. service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>