

LOCATION 543 Belfast Dr CITY GASTONIA
BETWEEN Brightington Dr STREET & Colebrook Dr STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>45'</u>	<u>1-10-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>2'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>43'</u>			

ENTERS: 543 BRANCHED INTO: 0

TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 180' E of Colebrook Dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1976

DEPTH: 3 FT. 0 IN. LOCATION 24' N of Belfast Dr

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 656801

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY