


LOCATION 3701 Bellevue TerraceCITY GastoniaBETWEEN Ancrest DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	$3/4$	P	136'		12-2-94	
MAIN TO PROP. LINE	$3/4$	P	45'		140' of 1" BARE	
PROP. LINE TO BLDG.	$3/4$	P	91'			

ENTERS: 3701 Bellevue Terrace BRANCHED INTO: —TAP SIZE: 1" Dress Tee PRESSURE 60 P.S.I. — INCHES W.C. LOCATION Left Side of HousePRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By S ElmerMAIN-SIZE 2 1/2 C.I. — BARE STEEL — COATED STEEL ✓ PLASTIC — YEAR INSTALLED 1958DEPTH: 2 Ft. 0 In. LOCATION 11' E of Bellevue Terr."A" P/S READING 20 TOTAL ANODES 1* — 17* — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY