

LOCATION 1606 + 1612 Belmar Dr. CITY EASTONIA  
BETWEEN Garland STREET & Kenworthy Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>7'</u>	<u>7-23-94</u>	<u>Tied over 144' EXIST</u>	<u>1612 - 3-3-86</u>
MAIN TO PROP. LINE					<u>ON 1606 3/4 Plastic</u>	<u>1606 - 3-3-86</u>
PROP. LINE TO BLDG.					<u>Tied over 39' 3/4</u> <u>PLASTIC ON 1612</u>	

ENTERS: 1606 Belmar Dr. BRANCHED INTO: 1612 Belmar Dr.  
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 207' S of C of Kenworthy Dr.


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RL

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 3 Ft. 0 In. LOCATION 20' W of C of Belmar Dr.

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # —

REMARKS: Bare Main Replacement Split Plastic 3/4 Services  
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY