

LOCATION 1700 Belmar dr.

CITY Gastonia

BETWEEN Garland

STREET & Cheelerfield

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	5'	7-23-99	Lead 94' of 3/4 C/W Ser.	
MAIN TO PROP. LINE					to Ext 2" P. Main	
PROP. LINE TO BLDG.						

ENTERS: 1701

BRANCHED INTO: —

TAP SIZE: 1/2

PRESSURE

P.S.I.

INCHES W.C.

LOCATION 20' W. of C of
Belmar dr.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By JP

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ☒ YEAR INSTALLED 1992

DEPTH: 3 Ft. 0 In.


LOCATION

"A" P/S READING P

TOTAL ANODES 1* 1 17* —

L.R. #

REMARKS: Bonded Ins dresser lead wire off at main



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	1.10
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY