

LOCATION 1532 Belmar dr. CITY Boston  
BETWEEN Chesterfield St STREET & Kimberly STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>7-23-94</u>	<u>tied over 124' 3/4 C/w</u>	
MAIN TO PROP. LINE					<u>Serv. to Ext 2" main</u>	
PROP. LINE TO BLDG.						

ENTERS: 1532 BRANCHED INTO: —  
TAP SIZE: 1/2 PRESSURE — P.S.I. — INCHES W.C. LOCATION 22' W. of C of  
Belmar dr.

PRESSURE TEST: @ 100 psi For 1/2 Hrs. By GP  
MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1992  
DEPTH: 3 Ft. 0 In. LOCATION —

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>1.40</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY