

LOCATION 1741 Belmar Dr CITY Oakton

BETWEEN Kimberly Dr STREET & Chesterfield Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>99'</u>		<u>8-18-93</u>	
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>94'</u>			

ENTERS 1741 Belmar Dr BRANCHED INTO -

TAP SIZE 1/2 PRESSURE 60 P S I INCHES W C LOCATION 'N of Kimberly Dr


PRESSURE TEST @ 100 psi For 1/4 Hrs By S. S. Sinner

MAIN - SIZE 2" C I - BARE STEEL - COATED STEEL - PLASTIC ✓ YEAR INSTALLED 1993

DEPTH 3 Ft 0 In. LOCATION 'W of Belmar Dr

"A" P/S READING P TOTAL ANODES 1# - 17# - L.R. # -

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>P</u>
P/S Pipeline Lead - White Existing Main	E	