

LOCATION

1801 Belmar Dr.

CITY

GASTONIA

BETWEEN

Kimberly Dr.

STREET &

310 West Ln.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	55'	9-24-96		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	50'			

ENTERS:

1801

BRANCHED INTO:

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

161' S. of center

of Kimberly Dr.

PRESSURE TEST:

@

100

psi

For

1/4

Hrs.

By

S. Huffstutz

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1993

DEPTH:

3 Ft.

0 In.

LOCATION

19' W. of center of Belmar Dr.

"A" P/S READING

P

TOTAL ANODES


1# 0

17# 0

L.R. #

520246

REMARKS:



Test Station

ENG. DEPT. USE ONLY

Reading & Location

Lead

Volts

P/S Pipeline Lead - Red
New Service

S

P/S Pipeline Lead - White
Existing Main

E