

LOCATION 112 N Belvedere Ave. CITY Gastonia

BETWEEN Davis Ave. STREET & Craig st. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P.</u>	<u>95'</u>			<u>5-20-97</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>32'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>63'</u>			

ENTERS: SAME

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 439' from @ of

Davis Ave


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY DHT

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1997

DEPTH: 0 FT. 0 IN. LOCATION Westside of Belvedere

"A" P/S READING P. TOTAL ANODES 1# _____ - 17# _____ I.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY